

RCC

(REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO
SALTEK

IN TERMS OF SANS 10142 CLAUSE 4.
ISSUED BY

National Regulator for Compulsory Specifications

PRODUCT: SURGE PROTECTIVE DEVICE (SALTEK) FLP-series T1 + T2;

$U_c = 260V AC(L-N)$, $I_n = 30kA$, $I_{max} = 60kA$, $I_{imp} = 25kA$;

$U_c = 255V AC(N-PE)$, $I_n = 50kA$; $I_{max} = 100kA$; $I_{imp} = 50kA$; Class I & Class II; IP20

Test Laboratory:
CTI Vienna-GmbH

In accordance to (Standards):
IEC 61643-11:2011

Test report no: CTI-CB 809-1/-2

RCC No: 1811122



NRCS Electro-Tech General Manager

Period of Validity

03/12/2018 to 03/12/2020

DATE 5/12/18

