

RCC

(REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO
SALTEK
IN TERMS OF SANS 10142 CLAUSE 4.
ISSUED BY

National Regulator for Compulsory Specifications

PRODUCT: SURGE PROTECTIVE DEVICE (SALTEK) SLP-275...; SLP-385...; SLP-NPE series ;
 $U_c = 275V AC(L-N)$, $U_p = 1.35kV$, $I_n = 20kA$, $I_{max} = 40kA$ & $U_c = 385V AC(L-N)$, $U_p = 1.8kV$, $I_n = 20kA$, $I_{max} = 40kA$
 $U_c = 255V AC(N-PE)$, $U_p = 1.5kV$, $I_n = 20kA$; $I_{max} = 40kA$; IP20

Test Laboratory:
CTI Vienna-GmbH

In accordance to(Standards):
IEC 61643-11: 2011

Test Report No: CTI-CB 843-1 to 843-2

RCC No: 1807071

Period of Validity
10/07/2018 to 10/07/2020

10/07/2018

DATE

[Signature]
NRCS – Electrbtechnical General Manager.

