

RCC

(REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO

DEHN + SÖHNE GmbH + Co.KG

IN TERMS OF SANS 10142 CLAUSE 4.
ISSUED BY

National Regulator for Compulsory Specifications

PRODUCT: SURGE PROTECTION DEVICE (DEHN)

DG S CI 275(FM); DG M TN CI 275(FM); DG M TT 2P CI 275(FM); DG M TNC CI 275(FM);

DG M TNS CI 275(FM); DG M TT CI 275(FM);

$U_n = 230V$, $U_c = 275V$, $I_{max} = 25kA$, $I_n = 12.5kA$, $U_p \leq 1.5kV$, 50/60Hz

Test Laboratory:

DEKRA Certification B.V

Test Report No(s): 2168398.50 to 55

RCC No: 1802035

In accordance to(Standards):

IEC 61643-11:2011 (E.d1)

Period of Validity

14/02/2018 to 14/02/2021

[Signature]
NRCS Electro-Tech General Manager



DATE

19 February 2018