

RCC

(REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO

DEHN + SÖHNE GmbH + Co.KG

IN TERMS OF SANS 10142 CLAUSE 4.

ISSUED BY

National Regulator for Compulsory Specifications

PRODUCT: SURGE PROTECTION DEVICE (DEHN)

DEHNVENTIL M SERIES; DVMTN255(FM); DVMTP2255(FM); DVMTC255(FM); DVMTNS255(FM);
DVMTT255(FM); $U_c = 255V$, $I_{max} = 25kA$ (L-N/PEN); $U_p \leq 1.5kV$ (L-N, N-PE); 25kA, 50kA, 100kA (N-PE), 50/60Hz

Test Laboratory:

DEKRA Certification B.V

Test Report No(s): 2163108.50 to 54

In accordance to (Standards):

IEC 61643-11: 2011(E.d1)

RCC No: 1802032

Period of Validity

13/02/2018 to 13/02/2021


NRCS Blecko-Tech General Manager

DATE

19 February 2018

